

INSPECTION DATE	Certified Elevator Inspector (CEI) #	Type of Inspection
7/15/2024	0726	Alteration Acceptance

Time In:
8:00:00 AM

Time Out:
5:00:00 PM

State of Florida
ELEVATOR INSPECTION REPORT

SERIAL NUMBER
35528

ATIS Elevator Inspections - REC# 709

Building Name:
SUMMIT OWNERS ASSOC INC

Building Address:
8743 Thomas Drive

City: Panama City Beach Zip Code: 32408

VIOLATIONS
Violation Codes @: www.MyFlorida.com/dbpr/hr/documents/violation_codes.xls

DEFINITIONS
CEI - FL Certified Elevator Inspector
CET - FL Certified Elevator Technician
REC - FL Registered Elevator Company

I certify that as the elevator company supervisor, I directly supervised the construction or installation of this elevator.
Or See attached elevator installation affidavit.

Signature:	CEI #	CET #
Print Name:	Phone Number:	

- VIOLATION 1:
- VIOLATION 2:
- VIOLATION 3:
- VIOLATION 4:
- VIOLATION 5:
- VIOLATION 6:
- VIOLATION 7:
- VIOLATION 8:
- VIOLATION 9:

Test Witness: DF (lbs): 15, UCM Up (in): 15, Car Slide (in): 10, Gov Elec (fpm): 400, Gov Mech (fpm): 450, UCM Dn (in): 34,

Maintenance Co:
Cavinder Elevator Company - Myrtle Beach SC

Bill To:

Person Receiving This Report - The inspection: Passed Generator Test Performed: No

If violations are cited, this report constitutes an Order to Correct as outlined in s. 399.061(4), Florida Statutes. Violations must be corrected within 90 days in accordance with s. 399.105(4), Florida Statutes.

Signature	Title
Print Name	Phone Number


I certify that I have personally performed or witnessed:

- Routine Inspection
- Periodic test as prescribed by ASME A17.
- Acceptance inspection of new or altered installation as recommend by the ASME A17.2 Inspectors Manual
- Violations cited on the previous inspection report have been corrected.
- Installation Meets or exceeds minimum standards of Chapter 399, Florida Statutes, and Chapter 30 of the Florida Administrative Code.

This device

- Complies With
- Does Not Comply With
- Is Exempt From

Section 399.15 - Florida Statutes: Access/Fire Key Requirements.

Signature:	CEI#	REC#
	0726	709
Print Name:	Phone Number:	
Darrell Green	(855) 755-2847	

Notes: Device Designation: 4